

PREBID QUERIES FOR FURNITURE & FURNISHING

Sl.No./ Item No.	Description	Pre-Bid Points	Reply
1		We request you to incorporate us in approved list of brands for 1. Dustbin & 2.Bought Out Furniture , which will enable us to bid in the tender. We assure you a superior product and look forward your support	1). Please refer clause no 41 of special condition of contract. However, it is clarified that if the specification/ quality/ shape/ size etc are not as per the tender conditions, the agency has to procure the item from the approved make list. In all such cases, the decision of the Engineer-in-Charge will be final and binding.
2	RECEPTION TABLE		
	<p>1. Top shall be made out of 19mm thick marine grade</p> <p>2. The bottom and top portion shall be fixed with 2nd class teak wood frame with synthetic enamel paint as per approved shade and color etc.</p> <p>3. Teak wood lipping (8 mm thick) will be provided on all the edges of the table.</p>	<p>1. 19mm thk ply is not available BWP (IS 710) hence we can provide 18 mm ply .</p> <p>2. The bottom and top portion shall be fixed with Solid wood frame with Mellamine Polish.</p> <p>3. All the exposed edge surfaces of board to be covered with PVC edge banding.</p>	<p>1). 18 mm thick ply confirming to IS 710 will be acceptable</p> <p>2). The description of item modified as " The bottom and top portion shall be fixed with 2nd class teak wood frame with mellamine Polish as per approved shade and color etc" in place of "The bottom and top portion shall be fixed with 2nd class teak wood frame with synthetic enamel paint as per approved shade and color etc."</p> <p>3). PVC edge banding in place of teak wood lipping shall be acceptable provided the same shall be done by automated edge banding machine using hot melt adhesive (779.6 thermo plastic synthetic resin).</p>

PREBID QUERIES FOR FURNITURE & FURNISHING

3	Wardrobes		
	<p>1. Top shall be made out of 19mm thick marine grade</p> <p>2. wooden lipping, Synthetic Enamel painting on hard wood (1st class teak wood) block, telescopic channel, rubber leg lowers as per shape, size and details as provided in the drawing</p> <p>3. The sliding drawer to be provided with 125 mm Hafele D type pull handle</p>	<p>1. 19mm thk ply is not available BWP (IS 710)hence we can provide 18 mm ply .</p> <p>2. All the exposed edge surfaces of board to be covered with PVC edge banding.</p> <p>3. The sliding drawer to be provided with Ebco Regular Handle.</p>	<p>1). 18 mm thick ply confirming to IS 710 will be acceptable</p> <p>2). PVC edge banding shall be accepted provided the same shall be done by automated edge banding machine using hot melt adhesive (779.6 thermo plastic synthetic resin).</p> <p>3). As per approved make only.</p>
4	Kitchen Under Counter Cabinets and Overhead Cabinets		
	<p>1. Top shall be made out of 19mm thick marine grade</p> <p>2. wooden lipping, Synthetic Enamel painting on hard wood (1st class teak wood) block, telescopic channel, rubber leg lowers as per shape, size and details as provided in the drawing</p> <p>3. The sliding drawer to be provided with 125 mm Hafele D type pull handle</p>	<p>1. 19mm thk ply is not available BWP (IS 710)hence we can provide 18 mm ply .</p> <p>2. All the exposed edge surfaces of board to be covered with PVC edge banding.</p> <p>3. The sliding drawer to be provided with Ebco Regular Handle.</p>	<p>1). 18 mm thick ply confirming to IS 710 will be acceptable</p> <p>2). PVC edge banding in place of teak wood lipping shall be acceptable provided the same shall be done by automated edge banding machine using hot melt adhesive (779.6 thermo plastic synthetic resin).</p> <p>3). As per approved make only.</p>
5	Kitchen Over head Counter Cabinets (Faculty Housing, Staff housing, Academic and Admin & faculty):		
	<p>1. Top shall be made out of 19mm thick marine grade</p> <p>2. wooden lipping, Synthetic Enamel painting on hard wood (1st class teak wood) block, telescopic channel, rubber leg lowers as per shape, size and details as provided in the drawing</p> <p>3. The sliding drawer to be provided with 125 mm Hafele D type pull handle</p>	<p>1. 19mm thk ply is not available BWP (IS 710) hence we can provide 18 mm ply .</p> <p>2. All the exposed edge surfaces of board to be covered with PVC edge banding.</p> <p>3. The sliding drawer to be provided with Ebco Regular Handle.</p>	<p>1). 18 mm thick ply confirming to IS 710 will be acceptable</p> <p>2). PVC edge banding shall be accepted provided the same shall be done by automated edge banding machine using hot melt adhesive (779.6 thermo plastic synthetic resin).</p> <p>3). As per approved make only.</p>

PREBID QUERIES FOR FURNITURE & FURNISHING

6	Pantry Cabinets / Credenza:		
	<p>1. Top shall be made out of 19mm thick marine grade</p> <p>2. wooden lipping, Synthetic Enamel painting on hard wood (1st class teak wood) block, telescopic channel, rubber leg lowers as per shape, size and details as provided in the drawing</p> <p>3. The sliding drawer to be provided with 125 mm Hafele D type pull handle</p>	<p>1. 19mm thk ply is not available BWP (IS 710) hence we can provide 18 mm ply .</p> <p>2. All the exposed edge surfaces of board to be covered with PVC edge banding.</p> <p>3. The sliding drawer to be provided with Ebco Regular Handle.</p>	<p>1). 18 mm thick ply confirming to IS 710 will be acceptable</p> <p>2). PVC edge banding in place of teak wood lipping shall be acceptable provided the same shall be done by automated edge banding machine using hot melt adhesive (779.6 thermo plastic synthetic resin).</p> <p>3). As per approved make only.</p>
7	Shoe Cabinet		
	<p>1. Supplying, and placing in position of shoe cabinet as per reference Image. The Shoe cabinet shall have 3 nos top opening sections with Slots for finger hold, with 2mm thk Powder coated MS shoe shelves for holdong shoes.</p>	<p>1. The shoe unit to be Top made from 18mm thk pre laminated Particle Board, & Side Shelf & Openable door made of 18mm thk pre laminated Particle Board . All exposed edges to have 2mm PVC edge banding.</p>	<p>The description of item modified as "The shoe unit to be made from 18mm thk pre laminated Particle Board, in a color/shade as per approval" in lace of "The shoe unit to be made from 25mm thk pre laminated Particle Board, in a color/shade as per approval".</p>
8		<p>All Plywood , Laminates & Veneer are Durian Make</p>	<p>Plywood , Laminates & Veneer of Durian Make may be accepted subject to the condition that the plywood & laminates shall be confirming to relevent IS codes.</p>
9		<p>All Hardware: Ebco Make</p>	<p>As per approved make only.</p>

PREBID QUERIES FOR FURNITURE & FURNISHING

10	Regarding list of approved makes	There are few brands mentioned in List of approved makes like “ IDUS /SKV /Bristol /Monarch/ Spacewood /Durian ” in furniture items & Spacewood /SKV India / Godrej in Modular Kitchen. You are requested to please include our brand (INDO INNOVATIONS) also in this tender	As per tender conditions only.
11	Regarding part quote	If vendor is allowed to quote partly products, i.e. only sofa,table,etc.	No. Please refer clause no 10 at page no 10 of Notice Inviting tender.
12	Regarding EMD & Tender cost	MSME (Udyog Aadhar) certified firm are exempted from submission on EMD and tender fee, same like other central government institutes-IITs, NITs, IISERs,AIIMS, etc.	MSME bidders possessing enlistment certificate from NSIC are not required to submit any Bank Draft towards EMD and Cost of Tender. However, they have to upload the enlistment certificate.

Note:- This prebid clarification will form part of the tender document. Rates shall be quoted after taking into consideration of the above modifications.